DATE: 11/22/2023 ATS, Inc, W. Bellis, P.E.

## OCEANO COMMUNITY SERVICES DISTRICT WATER STORAGE TANK REHABILITATION PROJECT CONTRACT NO. 2023-03 ADDENDUM #1

This addendum forms a part of the Contract Documents and modifies the original Procurement Documents, as noted herein. Each bidder shall acknowledge receipt of this Addendum by completing the acknowledgment at the end of this Addendum, and by confirming receipt of this addendum on their bid proposal. Failure to do so may subject Bidder to disqualification.

The following changes or clarifications have been made to the Bid Documents:

## **REVISIONS TO THE PROJECT MANUAL**

REVISION A: SECTION 01100, SCOPE AND CONTROL OF THE WORK, PART 1- GENERAL, 1.01 SCOPE-A Revise by adding the following after the second sentence:

Zinc rich primer is present on the interior and exterior coatings. The Contractor shall assume that zinc is present in the existing coatings at levels defined as hazardous.

**REVISION B:** SECTION 01205, MEASUREMENT AND PAYMENT, PART 3 - EXECUTION - 3.04 BID ITEMS, H. Demobilization, revise paragraph 1-b. by adding the following to the end:

Documentation of proper disposal of dusts and other contaminated materials shall be provided to the District. Abrasives shall be recycled pursuant to the California Health and Safety Code (HSC, Division 20, Chapter 6.5, Article 4, Section 25143.2) and other applicable regulatory requirements. Documentation of recycling shall be provided to the District.

## REVISION C: SECTION 09905, PROTECTIVE COATINGS, PART 1- GENERAL, 1.04 SUBMITTALS,

- **B.** revise by adding item 10 (after item 9) as follows:
- 10. Scaffold plan stamped by a Civil or Structural Engineer. Plan shall include maximum allowable sustained winds for wrapped (containment) and scaffold without wrap along with an action plan for winds exceeding the design allowable.

**REVISION D:** SECTION 09905, PROTECTIVE COATINGS, PART 3 - EXECUTION - 3.02 PROTECTION OF PROPERTY, A. revise paragraph A by adding the following to the end:

The containment system shall comply with SSPC Guide 6 for Dry Abrasive Blast Cleaning - Full Containment with Negative Pressure (SSPC Class 1A).